5) NET 15/ LW/201/2013-29



Veena Fire & Safety Service

An ISO-9001:2015 Certified Company

All types of safety equipments supplier & Maintenances

Training Imparted:

1)Fire fighting training & demonstration 2) Emergency Kit, Cl2 Kit training & demonstration 3) Self contain breathing apparatus (SCBA) training & Demonstration. 4) PPE's (Personnel protective equipments training & demonstration;

Register Office : At. Post : Peer Lote (Peermal), Tal: Khed, Dist : Ratnagiri 415722, Cell : 7722063666, 7775085304, 8378019404, Ph; (02356) 272589, Email : sunil.safetyspm.more@gmail.com

Date: 03.07.2023

TO WHOMSOEVER IT MAY CONCERN

THIS IS CERTIFY THAT WE CARRIED OUT THE REFILLING,/ HYDRAULIC PRESSURE TESTING OF BELOW MENTION FIRE EXTINGUISHERS WHICH ARE BELONGS TO:

NAME

: SHREE SAMARTHA KRUPA ENGLISH MEDIUM SCHOOL

ADDRESS: A/p- Veral Tal.- Khed, Dist.- Ratnagiri

Mob. No. / Phone No. : 02356 260420

AT AS PER IS 2190 ON DATED : 03rd JULY 2023

THE DETAILS OF TESTING IS AS HERE UNDER

1	Type Of Fire Extinguisher	Capacity	ID NO.	Tested to Pressure	Duration	Remark
1	ABC FIRE	2 Kgs.	01,02,03,04,05,	30 Kg./Cm2	2.5 min.	Found Ok
•	EXTINGUISHER		06,07,08,09,10			

ABOVE FIRE EXTINGUISHRES ARE GOOD AND OPERATABLE CONDITION

NEXT DUE DATE OF REFILLING IS : 02nd JULY 2024

For

M/s VEENA FIRE & SAFETY SERVICE, LOTE

Manager

Too Samarth Krupa Eng. Med. School, Veral

Principal

Shree Samarth Krupa English Medium School

Varus, Tal, Khed, Dist, Rasnegiri.